

**ADDENDUM 1
TO THE CONTRACT PROVISIONS AND CONTRACT PLANS**

FOR

**CITY OF WOODLAND
FILTERS 2 AND 3 RESTORATION AND MEDIA REPLACEMENT**

G&O #23607

ISSUED THIS DATE: FRIDAY, DECEMBER 15, 2023

**BID SUBMITTAL: 10:00 A.M. (LOCAL TIME) ON
WEDNESDAY, DECEMBER 20, 2023
CITY OF WOODLAND
230 DAVIDSON AVENUE
WOODLAND, WASHINGTON 998674**



Bidder shall acknowledge receipt of this Addendum on Page P-5 of the Proposal.

TO PROSPECTIVE BIDDERS:

The attention of all prospective bidders on the above project is directed to the following additions and modifications to the Contract Provisions and Contract Plans.

I. ADDITIONS, MODIFICATIONS, AND/OR DELETIONS TO THE CALL FOR BIDS

ITEM 1:

CB-2, Call for Bids

ADD the following before the last paragraph of this page:

“All general contractors and all subcontractors must meet DWSRF requirements or provisions.

All contractors must be licensed to conduct business in Washington State.”

II. ADDITIONS, MODIFICATIONS, AND/OR DELETIONS TO THE TECHNICAL SPECIFICATIONS

ITEM 1:

Page 11250-1, Specification Section 11250-2.1, APPROVED MANUFACTURERS

REVISE the second sentence as follows:

Media shall be as supplied by Leopold, Loprest, CEI, *Westech*, or approved equal.

ITEM 2:

Page 11250-2, Specification Section 11250-2.7, GARNET

DELETE the paragraph in its entirety and **REPLACE** with the following:

“The high density sand shall be 0.20 to 0.32 mm garnet. The garnet shall have a minimum specific gravity of 3.8 with a uniformity coefficient of 1.7 or less. Acid solubility shall be 0.1 percent.”

ITEM 3:

Page 11250-3, Specification Section 11250-2.9, ANTHRACITE

DELETE the paragraph in its entirety and **REPLACE** with the following:

“The anthracite shall be 1.0 to 1.1 mm with a uniformity coefficient of 1.7 or less. Anthracite shall have a specific gravity greater than 1.4, acid solubility of <5 percent, Moh’s hardness of 3.0, and moisture content of <2 percent.”